LPCB®

www.redbooklive.com

Certificate of Product Approval

Certificate Number: 531f-(cl-1)

lssue: 06

Siemens Switzerland Ltd

Theilerstrasse 1a CH-6300 Zug Switzerland

is certified by BRE Global Ltd. and is authorised to use the LPCB mark in association with the product(s) listed in this certificate and appendix having complied with the requirement(s) of the standards as detailed below:

Products

Heat Detectors HI720 HI722 HI360 (refer to Appendix for details)

Standards

EN 54-5:2000 + A1:2002 EN 54-17:2005

PКЕ

This Certificate is maintained and held in force through regular surveillance activities and subject to the corresponding ISO 9001 Certificate being maintained.

P. Walligar.	P Halligan	10 September 2020	4 December 2009	
Signed for BRE Global Ltd	Verifier	Date of Issue	Date of First Issue	



This certificate and appendix remains the property of BRE Global Ltd. and is issued subject to terms and conditions (for details visit <u>www.redbooklive.com/terms)</u>. To check the validity of this certificate and appendix please visit <u>www.redbooklive.com/check</u>, scan the QR tag or contact us. BRE Global Ltd, Watford, WD25 9XX

T: +44 (0)333 321 8811 E: <u>enquiries@breglobal.com</u> LPCB is a Registered Trademark of the Building Research Establishment Ltd.



80018

Appendix to Certificate No: 531f-(cl-1)

Issue: 06

Siemens Switzerland Ltd

LPCB[®]

Certified Product	Description	LPCB Ref.No.
HI720	Analogue Addressable Class A2S and A2R Heat Detector with Short Circuit Isolator (DB720, DB721, DB722 bases, BA720, BA721 base adaptor) Notes: 1. Meets the requirements of EN 54-5 at classes A2S and A2R	531f/01
HI722	Analogue Addressable Class A2S Heat Detector with Short Circuit Isolator (DB720, DB721, DB722 bases, BA720, BA721 base adaptor) Notes: 1. Meets the requirements of EN 54-5 at class A2S	531f/02
HI360	Analogue Addressable Class A2S and A2R Heat Detector with Short Circuit Isolator (DB721, DB722, DB720 bases, BA720, BA721 base adaptor) Note: 1. Meets the requirements of EN 54-5 at classes A2S and A2R	531f/05

Bases

DB720 Detector base DB721 Detector base with loop contact DB722 Detector base BA720 base adaptor BA721 base adaptor

This Certificate is maintained and held in force through regular surveillance activities and subject to the corresponding ISO 9001 Certificate being maintained.

f.//ellgen	P Halligan	10 September 2020	4 December 2009
Signed for BRE Global Ltd	^{Verifier}	Date of Issue	Date of First Issue
LPCB CERTIA CR CR CR CR CR CR CR CR CR CR	subject to terms and conditions (for To check the validity of this certific <u>www.redbooklive.com/check</u> , scar BRE Global Ltd, Watford, WD25 9 T: +44 (0)333 321 8811 E: <u>enquir</u>	the QR tag or contact us. XX	

80018