

Certificate of Product Approval

Certificate Number: 531e-(cl-1) Issue: 06



Siemens Switzerland Ltd

Theilerstrasse 1a CH-6300 Zug Switzerland

is certified by BRE Global Ltd. and is authorised to use the LPCB mark in association with the product(s) listec in this certificate and appendix having complied with the requirement(s) of the standards as detailed below:

Products

Smoke DetectorOP720
OP360
(refer to Appendix for details)

Standards

EN 54-7:2000 + A1:2002 + A2:2006 EN 54-17:2005

This Certificate is maintained and held in force through regular surveillance activities and subject to the corresponding ISO 9001 Certificate being maintained.

Signed for BRE Global Ltd

P Halligan

10 September 2020 Date of Issue 4 December 2009

Date of First Issue





This certificate and appendix remains the property of BRE Global Ltd. and is issued subject to terms and conditions (for details visit www.redbooklive.com/terms).

To check the validity of this certificate and appendix please visit www.redbooklive.com/check, scan the QR tag or contact us.

BRE Global Ltd, Watford, WD25 9XX

T: +44 (0)333 321 8811 E: enquiries@breglobal.com

LPCB is a Registered Trademark of the Building Research Establishment Ltd.







Appendix to Certificate No: 531e-(cl-1) Issue: 06

Siemens Switzerland Ltd

Certified Product	Description	LPCB Ref.No.
OP720	Analogue Addressable Optical Smoke Detector with Short Circuit Isolator (DB720, DB721, DB722 bases, BA720, BA721 base adaptor) Note: 1. Meets the requirements of EN 54-7 in the following sensitivities: - Standard 2.5%/m - Sensitive 1.8%/m	531e/01
OP360	Analogue Addressable Optical Smoke Detector with Short Circuit Isolator (DB720, DB721, DB722 bases, BA720, BA721 base adaptor) Note: 1. Meets the requirements of EN 54-7 in the following sensitivity: - Standard 2.5%/m	531e/04

Bases

DB720 Detector base

DB721 Detector base with loop contact

DB722 Detector base

BA720 Base adaptor

BA721 Base adaptor

This Certificate is maintained and held in force through regular surveillance activities and subject to the corresponding ISO 9001 Certificate being maintained.



P Halligan

10 September 2020

4 December 2009

Date of First Issue





This certificate and appendix remains the property of BRE Global Ltd. and is issued subject to terms and conditions (for details visit www.redbooklive.com/terms).

Date of Issue

To check the validity of this certificate and appendix please visit www.redbooklive.com/check, scan the QR tag or contact us.

BRE Global Ltd, Watford, WD25 9XX

T: +44 (0)333 321 8811 E: enquiries@breglobal.com

LPCB is a Registered Trademark of the Building Research Establishment Ltd.



