

BRE Global Ireland

Notified Body No. 2831
BRE Global Assurance (Ireland) Limited
DCU Alpha, Old Finglas Road
Glasnevin, Dublin, D11 KXN4
Ireland
T: +353 (0) 18824344
E: enquiries@breglobalireland.ie
www.breglobalireland.ie

Certificate of constancy of performance 2831-CPR-F4419

In compliance with Regulation (EU) No. 305/2011 of the European Parliament and of the Council of 9th March 2011 (the Construction Products Regulation or CPR), this certificate applies to the construction product(s)

HI360 Analogue Addressable Class A2S and A2R Heat Detector with Short Circuit Isolator
(For full product details and conditions of use refer to appendix)

Placed on the market under the name or trade mark of:

Siemens Switzerland Ltd
Theilerstrasse 1a
CH-6300 Zug
Switzerland

and produced in the manufacturing plant(s):

BEIJING SIEMENS CERBERUS ELECTRONICS LIMITED
No. 1, Feng Zhi Dong Lu
Xi Bei Wang
Haidian District
Beijing 100094
China

This certificate attests that all provisions concerning the assessment and verification of constancy of performance described in Annex ZA of the standard(s)

EN 54-5:2000 + A1:2002 - Heat Detectors
EN 54-17:2005 - Short Circuit Isolators

under system 1 for the performance set out in this certificate are applied and that the factory production control conducted by the manufacturer is assessed to ensure

the constancy of performance of the construction product.

This certificate was first issued on 02 September 2020 and will remain valid as long as neither the harmonised standard, the construction product, the AVCP methods nor the manufacturing conditions in the plant are modified significantly, unless suspended or withdrawn by the notified product certification body.



P Halligan, Certification Engineer

Date of First Issue: 02 September 2020

Date of Issue: 10 September 2020

On behalf of BRE Global Assurance (Ireland) Limited

Issue number 02

To check the validity of this certificate, please contact us on +353 (0) 18824344 or email enquiries@breglobalireland.ie

BRE Global Ireland

Notified Body No. 2831

BRE Global Assurance (Ireland) Limited
DCU Alpha, Old Finglas Road
Glasnevin, Dublin, D11 KXN4
Ireland

T: +353 (0) 18824344

E: enquiries@breglobalireland.ie
www.breglobalireland.ie

APPENDIX to Certificate of constancy of performance: 2831-CPR-F4419

HI360 Analogue Addressable Class A2S and A2R Heat Detector with Short Circuit Isolator

Note:

1. Meets the requirements of EN 54-5 at classes A2S and A2R

Bases:

DB720 Detector base
DB721 Detector base with loop contact
DB722 Detector base
BA720 Base adaptor
BA721 Base adaptor



P Halligan, Certification Engineer,

On behalf of BRE Global Assurance (Ireland) Limited

Date of First Issue: 02 September 2020

Date of issue: 10 September 2020

Issue number: 02

To check the validity of this certificate, please contact us on +353 (0) 18824344 or email enquiries@breglobalireland.ie